

Venti A/S  
Banevænget  
8362 Høring  
Denmark

Date 27-04-2021  
Init: MWE  
E-mail: [MWE@dbigroup.dk](mailto:MWE@dbigroup.dk)  
Phone: +45 50 80 78 40

### **Classification confirmation letter**

---

This letter is to confirm that the Venti Rectangular duct system is classified in accordance with EN 13501-3 as:

**Fire resistance classification:** E60 (ve ho i → o)\*

\* E60 is satisfied by fire from inside in both vertical and horizontal orientation.

For full details of the Venti Rectangular duct system, one should refer to DBI Classification Report PCA10675A. The classification given in PCA10675A is only valid if all the requirements listed in the report is fulfilled. This includes choice of specific materials and specific installation method. Deviations are not allowed.

**Danish Institute of Fire and Security Technology**



---

**Marlene Westmose**  
M.Sc.(Civ.Eng.)