



Pos indicative

Supply air		Exhaust air		a		Client:		Offer	Drawing nr.
Airflow	m ³ /h	25.000	Airflow	m ³ /h	25.000	b		23/0028	002
Ext. pressure	Pa	300	Ext. pressure	Pa	300	c		Project :	ZHK Inova
Tot. pressure	Pa	719	Tot. pressure	Pa	724	d		ZL 24/15 - AL 24/12	
Motor power	kW	2 x 5,000 / /	Motor power	kW	2 x 5,000 / /	e		Access side:	Position Nr.
Power supply		3x400 V - 50 Hz	Power supply		3x400 V - 50 Hz	f		See drawing	002
PHW-heating	kW	117,44	DX-cooling	kW	73,01	g		Date:	Unit:
CX-heating	kW	91,89				No.	Änderung	11-01-2023	50m olympic pool
						Date	Name	Name :	
								Venti	
								checked:	
								scale:	
								1:63	
								Delivery sections:	
								1	
								Total weight ca.:	
								5.455 kg	

